

G1909PCC Safety Station with WideArea™ Eye/Face Wash, Polished Chrome Construction

Application: Combination WideArea[™] eye/face wash and shower safety station. Unit is constructed of polished chrome plated brass pipe, fittings and components for attractive appearance and superior durability. Eye/face wash features four GS-Plus[™] spray- type outlet heads that deliver a flood of water over a wide area of coverage for complete rinsing of eyes and face.

Shower Head: 10" diameter stainless steel with 20 GPM flow control

Shower Valve: 1" IPS chrome plated brass stay-open ball valve. Valve is US-made with chrome plated brass ball and PTFE seals. Furnished with stainless steel actuating arm and 29" stainless steel pull rod.

Spray Head Assembly: Four GS-Plus[™] spray heads. Each head has a "flip top" dust cover, internal flow control and filter to remove impurities from water flow.

Eye/Face Wash Bowl: 11-1/8" diameter stainless steel.

Eye/Face Wash Valve: 1/2" IPS chrome plated brass stayopen ball valve. Valve is US-made with chrome plated brass ball and PTFE seals.

Pipe And Fittings: Polished chrome plated brass.

Supply: 1-1/4" NPT female top inlet.

Waste: 1-1/4 NPT female outlet. Outlet can be positioned at either 8-1/4" or 20-1/4" above finished floor by reversing lower pipe nipples.

Sign: ANSI-compliant identification sign.

Quality Assurance: Valve and spray head assemblies are factory assembled and water tested prior to shipment.

Available Options

- AP275-200 Electric flashing light and alarm horn unit for mounting on wall or vertical pipe. Light illuminates and horn sounds when eye/face wash or shower is activated. Furnished complete with flow switch and mounting hardware.
- **AP250-015** Modesty curtain for mounting on safety station.
- **G3800LF** Thermostatic mixing valve precisely blends hot and cold water to deliver warm (tepid) water as required by ANSI Z358.1-2014. Refer to "Tempering Valves" section for complete technical and product selection information.



Listed 8116. Units have been tested to and comply with

ANSI Z358.1-2014 and the

Uniform Plumbing Code.



312 447 8100 TELEPHONE gesafety.com





G1909PCC Safety Station with WideArea™ Eye/Face Wash, Polished Chrome Construction



Guardian Equipment 1140 N North Branch St Chicago, IL 60642 312 447 8100 TELEPHONE 312 447 8101 FACSIMILE gesafety.com Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code.

