

## **G1993** Safety Station with Eye/Face Wash, PVC Construction with Stainless Steel Valves

**Application:** All-PVC combination eye/face wash and shower safety station. Unit is constructed of PVC, PVC-coated components and stainless steel valves for superior corrosion resistance. Ideal for industrial environments where harsh acids or caustics are present. Eye/face wash features two large FS-Plus<sup>™</sup> spray-type outlet heads that deliver a flood of water for rinsing eyes and face.

Shower Head: 10" diameter orange ABS plastic with 20 GPM flow control.

Shower Valve: 1" IPS Type 316 stainless steel stay-open ball valve. Valve has stainless steel ball and PTFE seals. Furnished with stainless steel actuating arm and 29" stainless steel pull rod.

Spray Head Assembly: Two FS-Plus<sup>™</sup> spray heads. Each head has a "flip top" dust cover, internal flow control and filter to remove impurities from water flow.

**Eye/Face Wash Bowl:** 11-3/4" diameter orange ABS plastic.

Eye/Face Wash Valve: 1/2" IPS Type 316 stainless steel stayopen ball valve. Valve has stainless steel ball and PTFE seals.

Pipe and Fittings: Schedule 80 PVC.

Supply: 2" IPS socket weld top female inlet.

Waste: 2" IPS socket weld female outlet.

Sign: ANSI-compliant identification sign.

**Quality Assurance:** Valve and spray head assemblies are factory assembled and water tested prior to shipment.

## **Available Options**

- **G6040** Thermostatic mixing valve precisely blends hot and cold water to deliver tepid water as required by ANSI Z358.1-2014. Refer to "Thermostatic Mixing Valves" section for complete technical and product selection information.
- **GRN** Green ABS plastic shower head and bowl.
- **YEL** Yellow ABS plastic shower head and bowl.
- **SSH** Stainless steel shower head.
- AP275-200 Electric flashing light and alarm horn unit for mounting on wall or vertical pipe. Light illuminates and horn sounds when eye/face wash or shower is activated. Furnished complete with flow switch and mounting hardware.



Listed 8116. Units have been tested to and comply with

ANSI Z358.1-2014 and the

Uniform Plumbing Code.




312 447 8100 TELEPHONE 312 447 8101 FACSIMILE gesafety.com





## **G1993** Safety Station with Eye/Face Wash, PVC Construction with Stainless Steel Valves



Due to continuing product improvement, the information contained in this document is subject to change without notice. All dimensions are ± 1/4" (6mm). rev. 021023

Guardian Equipment 1140 N North Branch St Chicago, IL 60642

312 447 8100 TELEPHONE 312 447 8101 FACSIMILE gesafety.com

Listed 8116. Units have been tested to and comply with ANSI Z358.1-2014 and the Uniform Plumbing Code.

www.safetyemporium.com

